

PRODUCT CONFORMITY CERTIFICATE

This is to certify that the

AquaTrans AT600 ultrasonic flowmeter

Manufactured by:

Baker Hughes

Sensing House
Shannon Free Zone East
Shannon
County Clare
Ireland

has been assessed by CSA Group
and for the conditions stated on this certificate complies with:

**Performance Standards and Test Procedures for Continuous Water
Monitoring Equipment, Part 3: Performance standards and test procedures for water
flowmeters, Environment Agency, version 4, March 2020**

The combined performance characteristic (U_c , the expanded uncertainty) is as follows:
AquaTrans AT600 (AC) is 4.15% (**Class 2**)

Certification Range:

Velocity: 0.25m/s to 5m/s
Size: DN50 to DN1200

Project No.: 80083931
Certificate No: CSA MC250380/00
Initial certification: 20 August 2025
Certificate issued: 20 August 2025
Renewal date: 19 August 2030



Andrew Young
Environmental Team Manager

MCERTS is operated on behalf of the Environment Agency by

CSA Group Testing UK Ltd

Unit 6, Hawarden Industrial Park
Hawarden, Deeside, CH5 3US
Tel: +44 (0)1244 670 900



*The MCERTS certificate consists of this document in its entirety.
For conditions of use, please consider all the information within.
This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Certificate Contents

Approved Site Application.....	2
Basis of Certification	2
Product Certified.....	3
Certified Performance	4
Description.....	10
General Notes	10

Approved Site Application

Any potential user should make sure, in consultation with the manufacturer, that the monitoring system is suitable for the intended application. For general guidance on monitoring techniques refer to the Environment Agency guidance available at www.mcerts.net

The product is suitable for use, where it is appropriate, for regulated applications such as abstraction, effluent discharge, ultraviolet disinfection and industrial processing.

The field test was carried out between the 13th December 2024 and the 13th March 2025 at a sewage treatment works in Shropshire, UK.

Basis of Certification

This certification is based on the following test report(s) and on CSA Group's assessment and ongoing surveillance of the product and the manufacturing process:

WRc Test report, ref. 'UC11411.1', "MCERTS Testing of the AT600 Ultrasonic Flow Meter", March 2016

WRc Test report, ref. 'UC15630 V2', "Baker Hughes AT600 Clamp on Ultrasonic Flow Meter", December 2021

CSA Evaluation report, ref. '80083931, incorporating report "Laboratory and Field test Results", May 2025

Certificate No: CSA MC250380/00
Certificate issued: 20 August 2025

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Product Certified

The AquaTrans AT600 clamp-on ultrasonic flowmeter measuring system consists of the following parts:

- Liquid flow transmitter with epoxy-coated weatherproof Type 4X/IP67 enclosure (168mm x 128mm x 61mm dimensions) in aluminium construction with graphic LCD display and six-button keypad.
- x2 clamp-on transducers (CRS401 & CRS402) - anodized aluminium with stainless steel strapping.

This certificate applies to all instruments with serial number M1120125, onwards.

Certificate No: CSA MC250380/00
Certificate issued: 20 August 2025

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Certified Performance

The instrument was evaluated for use under the following conditions:

Ambient Temperature Range: -19°C to +53°C

Instrument IP rating: IP67

The instrument meets **MCERTS Class 2** requirements for the combined performance characteristic as specified in Table 6 of the MCERTS performance standard. Details of individual performance characteristics are summarised below:

Test	Result expressed as % of the certification range				Other results	Class	MCERTS specification
	<0.5	<1	<2	<5			
LABORATORY TESTS							
General requirements/initial checks							
Protection against unauthorised access	Password protected unique to the device						cl. 3.1.2
Indicative device and/or analogue digital output signal	LCD and 4-20mA output incorporated						cl. 3.1.3
Units of measurement	Verified						cl. 3.1.6 & 3.1.7
Comparison of output values	Verified						cl. 6.1.4
Warm-up time*							cl. 6.1.2 - no specification assigned, to be reported
AT600	12 secs						
Combined performance characteristic (Uc)							cl. 6.4 - Table 6 - class specific
AT600	4.15					2	
Performance tests							
Loss of power* - AC	Settings retained for 20 parameters						cl. 6.3.1
Mean error, x							cl. 6.3.2 - Table 6 - class specific
DN65 with 401 transducer							
Test point 1			1.58			2	
Test point 2		-0.92					
Test point 3				-2.18			
Test point 4				-2.78			
Test point 5				-3.21			
Test point 6				-3.38			
Repeatability, U _R							cl. 6.3.2 - Table 6 - class specific
DN65 with 401 transducer							
Test point 1	0.22					1	
Test point 2	0.34						
Test point 3	0.41						
Test point 4	0.30						
Test point 5	0.24						
Test point 6	0.18						

Certificate No: CSA MC250380/00
Certificate issued: 20 August 2025

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Test	Result expressed as % of the certification range				Other results	Class	MCERTS specification	
	<0.5	<1	<2	<5				
Supply voltage*, X _V							cl. 6.3.3 - Table 6 - class specific	
AC mains powered, X _V (85V to 265V)	0.16					1	cl. 6.3.3.1 - table 6 - class specific	
DC powered, X _V (12V to 28V)	0.12						cl. 6.3.3.2 - Table 6 - class specific	
Output impedance*, X _O (10Ω to 800Ω)							cl. 6.3.4 - Table 6 - class specific	
AT600 with CRS 402 transducer	0.060					1		
AT600 with CRS 401 transducer	0.107							
Fluid temperature, X _{FT} (2°C to +27°C)							cl. 6.3.5 - Table 6 - class specific	
AT600		0.62				2		
Ambient air temperature*, X _T (-20°C to +53°C)							cl. 6.3.6 - Table 6 - class specific	
AT 600 with CRS 402 transducer		0.77				2		
Relative humidity*, X _{RH} (95%, -20°C to +53°C)							cl. 6.3.6 - Table 6 - class specific	
AT 600 with CRS 402 transducer	0.45					1		
Bi-directional flow							cl. 6.3.13 - no specification assigned, to be reported	
Mean error								
Plastic (ABS) TP1 (DN65) - 0.41m/s				-2.94				
Plastic (ABS) TP2 (DN65) - 1.75m/s			-1.13					
Plastic (ABS) TP3 (DN65) - 4.93m/s		-0.58						
Lined Ductile Iron - TP1 (DN65) - 0.27m/s				3.24				
Lined Ductile Iron - TP2 (DN65) - 0.43m/s			1.20					
Lined Ductile Iron - TP3 (DN65) - 1.01m/s	0.02							
Lined Ductile Iron - TP4 (DN65) - 1.75m/s	-0.32							
Lined Ductile Iron - TP5 (DN65) - 3.53m/s			-1.43					
Lined Ductile Iron - TP6 (DN65) - 4.79m/s			-1.40					
Repeatability								
Plastic (ABS) TP1 (DN65) - 0.41m/s		0.63						
Plastic (ABS) TP2 (DN65) - 1.75m/s	0.40							
Plastic (ABS) TP3 (DN65) - 4.93m/s	0.33							
Lined Ductile Iron - TP1 (DN65) - 0.27m/s	0.37							
Lined Ductile Iron - TP2 (DN65) - 0.43m/s		0.56						
Lined Ductile Iron - TP3 (DN65) - 1.01m/s		0.51						
Lined Ductile Iron - TP4 (DN65) - 1.75m/s	0.23							
Lined Ductile Iron - TP5 (DN65) - 3.53m/s	0.19							
Lined Ductile Iron - TP6 (DN65) - 4.79m/s	0.19							

Certificate No: CSA MC250380/00
Certificate issued: 20 August 2025

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Test	Result expressed as % of the certification range				Other results	Class	MCERTS specification
	<0.5	<1	<2	<5			
Effect of conduit material						cl. 6.3.16 - no specification assigned, to be reported	
Mean error							
Carbon Steel - TP1 (DN65) - 0.26m/s			1.58				
Carbon Steel - TP2 (DN65) - 0.42m/s		-0.92					
Carbon Steel - TP3 (DN65) - 1.02m/s				-2.18			
Carbon Steel - TP4 (DN65) - 1.76m/s				-2.78			
Carbon Steel - TP5 (DN65) - 3.53m/s				-3.21			
Carbon Steel - TP6 (DN65) - 4.87m/s				-3.38			
Lined Ductile Iron - TP1 (DN65) - 0.28m/s				3.65			
Lined Ductile Iron - TP2 (DN65) - 0.42m/s				2.17			
Lined Ductile Iron - TP3 (DN65) - 1.01m/s		0.56					
Lined Ductile Iron - TP4 (DN65) - 1.76m/s	-0.23						
Lined Ductile Iron - TP5 (DN65) - 3.53m/s			-1.56				
Lined Ductile Iron - TP6 (DN65) - 4.80m/s			-1.65				
Plastic (ABS) TP1 (DN65) - 0.24m/s				-2.78			
Plastic (ABS) TP2 (DN65) - 0.42m/s				-3.52			
Plastic (ABS) TP3 (DN65) - 1.02m/s			-1.19				
Plastic (ABS) TP4 (DN65) - 1.73m/s		-0.57					
Plastic (ABS) TP5 (DN65) - 3.52m/s	-0.16						
Plastic (ABS) TP6 (DN65) - 4.80m/s	-0.16						
Repeatability							
Carbon Steel - TP1 (DN65) - 0.26m/s	0.22						
Carbon Steel - TP2 (DN65) - 0.42m/s	0.34						
Carbon Steel - TP3 (DN65) - 1.02m/s	0.41						
Carbon Steel - TP4 (DN65) - 1.76m/s	0.30						
Carbon Steel - TP5 (DN65) - 3.53m/s	0.24						
Carbon Steel - TP6 (DN65) - 4.87m/s	0.18						
Lined Ductile Iron - TP1 (DN65) - 0.28m/s	0.43						
Lined Ductile Iron - TP2 (DN65) - 0.42m/s	0.28						
Lined Ductile Iron - TP3 (DN65) - 1.01m/s	0.09						
Lined Ductile Iron - TP4 (DN65) - 1.76m/s	0.10						
Lined Ductile Iron - TP5 (DN65) - 3.53m/s	0.12						
Lined Ductile Iron - TP6 (DN65) - 4.80m/s	0.21						
Plastic (ABS) TP1 (DN65) - 0.24m/s			1.00				
Plastic (ABS) TP2 (DN65) - 0.42m/s				2.34			
Plastic (ABS) TP3 (DN65) - 1.02m/s		0.95					
Plastic (ABS) TP4 (DN65) - 1.73m/s		0.50					
Plastic (ABS) TP5 (DN65) - 3.52m/s	0.29						
Plastic (ABS) TP6 (DN65) - 4.80m/s	0.12						

Certificate No: CSA MC250380/00
Certificate issued: 20 August 2025

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Test	Result expressed as % of the certification range				Other results	Class	MCERTS specification
	<0.5	<1	<2	<5			
Effect of conduit size** (notes 1 & 2)							cl. 6.3.17 - no specification assigned, to be reported
Mean error - with CRS 401 transducer							
SMALL - TP1 DN65			1.58				
SMALL - TP2 DN65		-0.92					
SMALL - TP3 DN65				-2.18			
SMALL - TP4 DN65				-2.78			
SMALL - TP5 DN65				-3.21			
SMALL - TP6 DN65				-3.38			
MEDIUM - TP1 DN600			-1.27				
MEDIUM - TP2 DN600		-0.75					
MEDIUM - TP3 DN600	0.09						
MEDIUM - TP4 DN600			1.53				
MEDIUM - TP5 DN600				5.96			
LARGE- TP1 DN1200			1.67				
LARGE- TP2 DN1200			1.51				
LARGE- TP3 DN1200	0.43						
LARGE- TP4 DN1200		0.93					
LARGE- TP5 DN1200			1.17				
Mean error - with CRS 402 transducer							cl. 6.3.17 - no specification assigned, to be reported
MEDIUM - TP1 DN600				3.68			
MEDIUM - TP2 DN600				3.84			
MEDIUM - TP3 DN600				4.66			
MEDIUM - TP4 DN600				4.65			
MEDIUM - TP5 DN600				5.11			

Certificate No: CSA MC250380/00
Certificate issued: 20 August 2025

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Test	Result expressed as % of the certification range				Other results	Class	MCERTS specification		
	<0.5	<1	<2	<5					
Effect of conduit size** (notes 1 & 2)							cl. 6.3.17 - no specification assigned, to be reported		
Repeatability- with CRS 401 transducer							cl. 6.3.17 - no specification assigned, to be reported		
SMALL - TP1 DN65	0.22								
SMALL - TP2 DN65	0.34								
SMALL - TP3 DN65	0.41								
SMALL - TP4 DN65	0.30								
SMALL - TP5 DN65	0.24								
SMALL - TP6 DN65	0.18								
MEDIUM - TP1 DN600				3.50					
MEDIUM - TP2 DN600				3.01					
MEDIUM - TP3 DN600				2.82					
MEDIUM - TP4 DN600				2.92					
MEDIUM - TP5 DN600	0.33								
LARGE- TP1 DN1200			1.67						
LARGE- TP2 DN1200			1.51						
LARGE- TP3 DN1200	0.43								
LARGE- TP4 DN1200		0.93							
LARGE- TP5 DN1200			1.17						
Repeatability- with CRS 402 transducer									
MEDIUM - TP1 DN600			1.55						
MEDIUM - TP2 DN600			1.22						
MEDIUM - TP3 DN600		0.52							
MEDIUM - TP4 DN600	0.27								
MEDIUM - TP5 DN600	0.26								
Response Time* (either increasing or decreasing flow)							cl. 6.3.19 - ≤30 seconds		
Increasing					9 secs				
Decreasing					11 secs				

Certificate No: CSA MC250380/00
Certificate issued: 20 August 2025

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Test	Parameter	Result	Class	MCERTS specification
FIELD TESTS				
Error under field conditions	Maximum error (%)	-4.21	2	cl. 7.3 - Table 6
	Minimum error (%)	0.62		
	Mean error (%)	-1.39		
	Proportion of errors ≤2%	83.3		
	Proportion of errors ≤5%	100		
	Proportion of errors ≤8%	100		
Up-time (%)		99.6 (note 3)		cl. 7.4 ≥95%
Maintenance		None (note 3)		cl. 7.5 - to be reported

Note 1: Tests marked '*' denote test data taken from WRc report ref. 'UC11411.1', all other data from 'UC15630 V2'.

Note 2: Tests marked '#' denote testing carried out for "Effect of conduit size" for the sizes DN600 and DN1200 at a third-party test laboratory. Test results were reported in the WRc test report ref. 'UC11411.1'.

Note 3: The flowmeter system was installed in late 2024 with data obtained between the 13th December and 13th March 2025 with a total scheduled operating time of 2,184 hours, or 131,040 minutes. Of the total operating time 131,040 minutes, 585 minutes were attributed to outage time. No maintenance was required during the field test.

Certificate No: CSA MC250380/00
Certificate issued: 20 August 2025

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Description

The AquaTrans AT600 is a non-intrusive ultrasonic flow meter for the measurement of liquids. It is designed for industrial applications, including water, wastewater and others. The AT600 consists of the AT600 electronics, a metal enclosure, the transducer system, and a clamp-on transducer fixture.

The AquaTrans AT600 features the latest hardware and firmware developments and a wide range of configurable options and outputs to cover a range of applications and interface with virtually any control system.

General Notes

1. This certificate is based upon the equipment tested. The Manufacturer is responsible for ensuring that on-going production complies with the standard(s) and performance criteria defined in this Certificate. The Manufacturer is required to maintain an approved quality management system controlling the manufacture of the certified product. Both the product and the quality management system shall be subject to regular surveillance according to 'Regulations Applicable to the Holders of CSA Certificates'.
2. The design of the product certified is defined in the CSA design schedule for certificate No. CSA MC250380/00.
3. If the certified product is found not to comply, CSA Group should be notified immediately at the address shown on this certificate.
4. The certification marks that can be applied to the product or used in publicity material are defined in 'Regulations Applicable to the Holders of CSA Certificates'.
5. This document remains the property of CSA Group and shall be returned when requested by CSA Group.

Certificate No: CSA MC250380/00
Certificate issued: 20 August 2025

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*